

Units 1 & 2, Wharton Street Ind Est Nechells, BIRMINGHAM West Midlands, B7 5TR United Kingdom tel +44 (0) 121 327 7881 landonkingsway@mwatechnology.com

## 10905809 Dry Riser Floor Cabinet

## **Specifications**

- Manufactured from 16 SWG Zintec Steel BS EN 10152 (Back box powder coated white).
- Architrave 3mm steel electro plated.
- Door Produced from 5mm checker plate complete with black embosed 'DRY RISER INLET' stainless steel label.
- Minimum required aperture 405mm wide x 605mm long.
- Complete with Budget Lock lock not visible
- Does not conform to BS5041-5, local fire authority approval required.
- Angled base to allow water run off.
- Supplied with bottom drain points.
- Door pivots open with stainless steel piano hinge.
- See LK15135 for inlet breaching valve.



